

The role of transmission investment in the coordination between generation and transmission in the liberalized power systems

Vincent Rious, Jean-Michel Glachant, Yannick Perez, Philippe Dessante

► To cite this version:

Vincent Rious, Jean-Michel Glachant, Yannick Perez, Philippe Dessante. The role of transmission investment in the coordination between generation and transmission in the liberalized power systems. 32nd IAEE International Conference, San Francisco, Jun 2009, SAN FRANCISCO, United States. 9 p. - Proceedings on line. hal-00423036

HAL Id: hal-00423036

<https://hal-supelec.archives-ouvertes.fr/hal-00423036>

Submitted on 9 Oct 2009

HAL is a multi-disciplinary open access archive for the deposit and dissemination of scientific research documents, whether they are published or not. The documents may come from teaching and research institutions in France or abroad, or from public or private research centers.

L'archive ouverte pluridisciplinaire **HAL**, est destinée au dépôt et à la diffusion de documents scientifiques de niveau recherche, publiés ou non, émanant des établissements d'enseignement et de recherche français ou étrangers, des laboratoires publics ou privés.

The role of transmission investment in the coordination between generation and transmission in the liberalized power systems

Vincent Rious¹, Jean-Michel Glachant², Yannick Perez³, Philippe Dessante¹

Abstract

This paper examines how transmission coordinates with generation to the long term in a liberalized power system. We rely on a modular analysis to separate the mechanisms of coordination between generation and transmission of electricity into distinct modules. The governance structure of transmission completes this analysis framework. We then show that in a logic of complementarity, this governance structure influences the options that TSO implements to manage effectively power flows. Although locational signals are necessary to guide the installation of new power plants, the governance structure explains that investment in network may be the only effective method of long-term coordination between generation and transmission.

Introduction

In liberalized power systems, to ensure non-discriminatory access to transmission network, it was needed to unbundle vertically competitive generation and the natural monopoly of transmission network. Unbundling activities previously integrated in a vertical and horizontal monopoly creates problems of coordination between generation and transmission investments. We show that transmission investment is the mechanism that will effectively realize this new coordination to the long term in a liberalised power system.

Facing this situation, Lévêque (2003) has shown that a centralized authority should send locational signals to generators to replace the traditional coordination. This centralized authority is called the Transmission System Operator (TSO). Therefore, we expect that the TSOs implement the best existing signals that should lead to efficient coordination between generation and transmission investments. But the study of TSOs shows that those who implement the more incentive locational signals are not those who experience the best coordination with generation. How to explain this paradox?

To answer this question, in the first section, we propose and build an ideal TSO. We will use this ideal TSO as a benchmark for the study of coordination between generation and transmission of real TSOs. In the second section, we show that the incentive structure of the ideal TSO is difficult to achieve because the governance of electricity transmission assets influences the implementation of power flow management. Finally, in the third section, we apply this modular and organisational framework to compare two TSOs, 1° Pennsylvania, Maryland and New Jersey (PJM), and 2° National Grid. Then we will see what the central mechanism to coordinate generation and transmission of electricity is in real organizations.

¹ Assistant Professors at Supélec, Department of Power Systems and Energy, 3 rue Joliot-Curie, 91192 Gif-sur-Yvette CEDEX

² Director of the « Florence School of Regulation » et of the « Loyola de Palacio » chaire at the European University Institute.

³ Tenure professor at the University Paris-Sud 11, ADIS-Groupe Réseaux Jean Monnet and associated researcher at the « Loyola de Palacio » chaire at the European University Institute.

1- Ideal organization of a TSO

To manage power flows, the Transmission System Operators realize three main tasks that range from very short term (a few minutes to several hours) to the very long term (5 to 20 years) (Brunekreeft *et al.*, 2005). These three missions are: i) the management of short run power flow externality on the transmission network; ii) the development of transport capacity, and iii) coordination with neighboring interconnected systems. To study the multiplicity of real grid operators, we have shown in Rious *et al.* (2008) the relevance of a modular analysis framework *à la* Clark and Baldwin (2000) and Wilson (2002) to classify the existing empirical diversity of TSOs. Here we need only to focus on two missions: the short run management of power flow externality and the development of transmission network. If we choose the optimal option for each of these two missions, an ideal TSO can be defined. It is a combination of "nodal pricing" and, under a benevolent regulation, of the minimization of the total cost of network (that is to say, to minimize the sum of the congestion cost and the investment cost of the network). We will detail these two points and see why nodal pricing and long-term development of the transmission network are the building blocks of the optimal organization of an ideal TSO.

First, the optimal short run management of power flow externalities is obtained with the system of nodal pricing of energy. Schweppe *et al.* (1988) show that an efficient power dispatch can be achieved through a system of nodal pricing of electricity whose clearing is constrained by the externalities associated with congestion of powerlines. This method has incentive virtues superior to those of the two other well-known power flow management schemes, zonal pricing⁴ and redispatch⁵. Thus nodal pricing determines a price of energy for each node of the network. These prices indicate the nodes where it is preferable to produce or consume one more megawatt taking into account the constraints of network capacity.

Figure 1 illustrates nodal pricing on a simple two-node congested network. There is only generation connected to the first node S and its cost is low. To the second node D, there is a quantity Q of inelastic load and also generation whose cost is high. These two nodes are linked by a single powerline SD whose transmission capacity is K. If we ignore the limited capacity of powerline when clearing the market, generation to node S is sufficient to supply load (to node D). The equilibrium price is unique and is P_E . This equilibrium induces a flow on line SD greater than the available transmission capacity K, that is to say $K < Q$. As a consequence, this equilibrium is not technically feasible. To incentivize generation to the nodes S and D to take into account congestion on the line SD, with nodal pricing, the generator at node S is paid a price P_S below the equilibrium price without congestion P_E and the generator at node D is paid P_D a price higher than P_E . In this case, the difference in value between the nodal prices reflects the social value of network externalities. This difference creates a surplus for the TSO called "congestion rent". And the constraints of network capacity limit the maximization of social welfare by a quantity called "congestion cost". The congestion rent is represented on Figure 1 by the grey rectangle and the congestion cost by the dark grey trapezoid.

⁴ Zonal pricing is similar to nodal pricing but only the most important network constraints are internalized in the pricing system of electricity market. The other minor constraints are managed by redispatch. This simplification from thousands of nodes to few zones is very sensitive to errors and gaming by generators.

⁵ When congestions are managed by redispatch, they are not internalized in the electricity market. The TSO manages congestion after the market clearing by modulating production of the adequate power stations. Redispatch thus does not emit any locational signal, except for the modulated power stations.




Figure 1 Graphical representation of nodal pricing on a congested two-node network

The second mechanism of coordination between generation and transmission is the long-term development of the power transmission grid. In theory, the management of power flow externalities can inform the TSO and the users of the network on the constraints related to the current state of operation of the network. But to the long run the TSO should also make efficient network investments to eliminate all the constraints on the grid that are economically excessive. If one considers by simplification that the TSO is benevolent and efficient, it must invest in order to reduce the social costs caused by the externalities of use of the network and so, in an equivalent way, to maximize social welfare.

Considering this definition of the ideal TSO, the observation of the modes of organizations of real TSOs reflects a large variety of combination of suboptimal management schemes of power flows. This variety can be explained beyond the technical constraints of power flow management by the different characteristics of the governance structures of the transmission grid.

2- Complementarities between the governance structure and the management of electricity flows

In the liberalized power system, the TSO can take different organisational forms or governance structures, according to whether he owns the property rights of the network he manages, and according to the form of regulation that is applied to this monopoly. The governance structure of the network modifies the incentives that the TSO can perceive from the management of power flows. In this section, first of all, we define the governance structure of the network by presenting its main components. Then, we show that the governance structure of the network influences the options that the TSO implements to manage power flows.

2- a) The governance and the incentive regulation of the network

The way the transmission grid is unbundled constitutes the ground of the governance structure of the network. Because it determines the degree of incentives that can be introduced into the regulation of this monopoly. Unbundling the transmission grid from competitive activities like generation or supply is currently considered essential. This vertical unbundling is of two degrees of intensity. The first level always includes the unbundling of short run system operation. Indeed, the withdrawal of system operation from incumbents is rather easy to impose in a process of liberalization because this activity represents a relatively small volume of investment and employment. To the contrary, the second degree of unbundling for ownership of the power grid depends on the possibility of forcing the incumbents to cede their network assets. This level of vertical unbundling is more difficult to produce at the time of competitive reforms. Indeed a pure generator faces competitive pressures and uncertainty from electricity markets. While the network is a source of regulated revenue that is guaranteed and recurring. This secured source of revenue is then very interesting and attractive for a generator in electricity markets where the companies are also judged on their financial performances.⁶

The choices of the level of network unbundling can also be influenced by the interactions so called “border effects” between interconnected power systems. If ownership and operation of a grid on a continental scale are strongly fragmented between a lot of distinct TSOs, the loop flows between these TSOs create many border effects that are difficult to deal with and that can reach critical values for the reliability of the system. Then, operation and ownership unbundling of the network in each the TSO’s zone may not be sufficient to internalize the “border effects” and solve the associated problems. A remedy is then to remove the “System Operation” part from incumbents and to recompose this function on a wider geographical area including several electric zones, under the operational authority of a new Independent System Operator (ISO). The horizontal integration of system operation on wide zones then allows to internalize the border effects between the previous zones of the incumbents (Costello, 2001; PJM, 2004b).

One can now distinguish two main families of TSOs in terms of degree of unbundling: the “heavy” TSO and the “light” TSO. A “heavy TSO” owns the network infrastructures that he operates. A “light TSO” does not own the network infrastructures that he operates. These modalities of grid unbundling are thus important at the same time to understand the efficiency of the governance of the transmission network but also its regulation as a monopoly. In the case of a “heavy” TSO, the regulator can impose an incentive regulation on the controllable costs of the network to set the income of this monopoly. Indeed, the potential financial risks of an incentive regulation are acceptable for a “heavy GRT” in terms of assets, equity and revenues. To the contrary, it is difficult for a regulator to incentivize strongly a “light TSO” because of its weak financial standing (few assets, little equity, low revenue). This is why the “light TSOs” are usually non-for-profit organizations, partly self-regulated by the market participants in its zone (Barker and al., 1997).⁷

⁶ Moreover, ownership of the network can make it possible for the generators to protect strategically their generation portfolios in the development plans of the network.

⁷ One will notice that the good functioning of this principle of self-regulation is efficient only under the assumption that there is no risk of collusion or capture of the TSO by a single group of interest (Boyce and Hallis, 2005).

2- b) The governance of the network and the management of power flows are complementary

A TSO does not have the same incentives to manage and develop its network depending on the combination between its governance structure and its method to manage short-term externalities. Depending on the implemented method, the management of externality can generate rent or cost for the TSO. Nodal pricing effectively allows an efficient dispatching of generation taking into account the network constraints. But congestion rent arising from this method gives a counter-incentive signal to the TSO for its own investment decisions. Indeed, nodal pricing can incentivize a TSO maximizing its profit to make congestion last (Pérez-Arriaga and Al, 1995). A TSO that internalizes power flow externalities with nodal pricing should then be subject to a more demanding regulation to ensure that the maximization of the TSO's profit is in line with the maximization of social welfare.

On the contrary, the method called "redispatch" is considered inefficient to internalize the power flow externalities because the TSO then deals with congestion out of the day-ahead electricity market. In this case, no short-run locational signal is transmitted to the users of the network who cannot then make efficient use of the transmission capacity. But this method has the advantage that the TSO directly bears the congestion cost arising from system operation. Consequently, the TSO can here maximize its profit by comparing the social cost of short term congestions with the long-term cost of investment and maintenance of the grid and thus naturally maximizes social welfare.

The structure of governance of the network and the design of the modules of power flow management must then be seen like a global system. The theoretical perfection would be to combine the options of the ideal TSO with a perimeter of heavy TSO, unbundled from generation and regulated with a strong but also incentivizing regulator. However the complementarities between the governance structure and the modules of power flow management lead to sub-optimal choices in the design of these modules. Compromises must then be realized between the control of the costs of the network and the design of the modules of power flow management.

The study of two TSOs will show in the following section that their structure of governance influences the choice of the mode of coordination between generation and transmission. Thus some TSOs favor internalization of externality by scarcity pricing with given network capacity, while others act directly on the cause of externality by investing and increasing the transmission capacity.

3- The comparison of two TSOs of reference: PJM and *National Grid*

The objective of this part is twofold. First, we study the consequences of the complementarities on TSOs of reference to explain their choices to manage flows of electricity. We will proceed in two stages. First of all, we will compare the options of power flow management implemented by each TSO with those of the ideal TSO. Then, we will show how the structure of governance of the network constrains the implementation of these options. We show finally that the structure of governance can correct the failure of some sub-optimal options of coordination.

From this comparison, the second objective of this section is to show that the effects of complementarities brought by the governance of the network alternatively focus on the choice between "internalize externality of use of the network related to congestion" or "to increase the capacity of the network to treat the cause of congestion". Then we will show that it seems very difficult to carry out these two tasks jointly.

3- a) Comparison of real TSOs to the ideal TSO

Now we will use our construction of ideal TSO as a point of comparison for the study of real TSOs. We consider two TSOs of reference in the international experiments of liberalization of the power systems.

The first, PJM, is a light TSO structured as a non-for-profit organization that operates in the North-East of the United States. PJM is recognized as a model because the nodal pricing enabled him to extend its area of responsibility over a wide part for the North-East of the United States and to become thus the TSO that manages the higher peak load in the world (Joskow, 2006). In spite of the implementation of the best method of internalization, the congestion cost of this zone strongly increased until 2006. In fact, before April 2004, PJM didn't take into account the possibility to reduce congestion cost in the planning of network investments on its zone. The network investments were made only for technical reasons of reliability.

The second model is the TSO National Grid. It is a heavy TSO, owner of the network he operates in England and Wales. He is unbundled from generation. He operates, maintains and develops the network of England and Wales. National Grid is a private company, quoted on the stock exchange, but regulated by the British regulator of energy, the OFGEM⁸ (Joskow, 2006). This TSO is often quoted as an example for its efficiency in the management of the network within the framework of a liberalized power system (Rossignoli *et al.* 2005). While at the same time National Grid operates its system with redispatch and this option of congestion management does not internalize the externalities of use of the network. But the practical modalities of regulation applied to this monopolist for his system operation and the development of its network push it to invest in order to minimize congestion cost. Its congestion and investment costs have then be considerably reduced.

We note that these two TSOs do not apply the combination of coordination mechanisms of the ideal TSO. And this, although they are both recognized at the international scales for the management of their network. In addition, the trend of congestion cost of TSOs is not coherent with the locational signals used by each one of these TSOs. Indeed, it is paradoxical that PJM sees congestion increased whereas its locational signals are very incentive. In the same way, it is paradoxical that National Grid has a good control of congestion, whereas its locational signals are theoretically weaker.

In the following table, we summarize the comparison of these two TSOs, PJM and National Grid, with the ideal TSO, as well as the evolution of their congestion costs.

Table of comparison of different TSOs			
	Ideal TSO	PJM	NGC
<i>Congestion management</i>	+ Nodal pricing	+ Nodal pricing	- Redispatch
<i>Investment</i>	+ Social welfare maximization	- Decrease of congestion cost not considered	+ Arbitrage between congestion and investment costs
<i>Evolution of Congestion</i>		↗	↘

Sources: Joskow (2006) and Rossignoli *et al.* 2005

⁸ Office of Gas and Electricity Markets

3- b) Governance of the network and consequences on the options of congestion management

The structure of governance of the network that completes our initial framework of analysis makes it possible to explain the options implemented by the TSOs and their performances to coordinate generation and transmission of electricity. In particular, the type of network unbundling is central because it determines the most suitable regulation that can be applied to the TSO.

In the case of PJM, the grid remains the property of incumbents. The structure of “light TSO” of PJM has the advantage that it can be easily extended to integrate new zones in its market. This extension is all the more efficient as it is carried out thanks to nodal pricing of energy. The use of this method proves to be obligatory in the case of a light TSO like PJM because, by nature, PJM is insensitive to the congestion cost or the congestion rent resulting from the short run signals. Nevertheless, nodal pricing did not prevent a recrudescence of congestion on the zone of PJM.

The increase of congestion revealed in fact an insufficient coordination between generation and transmission within PJM. This problem ended up by drawing attention of the federal regulator of energy, the FERC (PJM, 2004b; Joskow, 2005). Thus, it is only under the pressure of the FERC that PJM defined the concept of “Economic Planned Transmission Facilities” (Joskow, 2006). Without the constraint of the regulator, PJM would probably not have taken this initiative because its statute of light TSO does not incentivize him to do it. Indeed, the heart of its activity is the short-term management of grid and it is thus the extension of this activity of system operation which guides the development of PJM.

Conversely, when the TSO owns the network like National Grid, the development of the infrastructure is its core activity. Network ownership then makes it possible to impose him an incentive regulation. Then, making him bear even only in part the congestion cost arising from redispatch incentivizes him to develop the network efficiently. Indeed, thanks to the structure of governance of heavy TSO of National Grid, an incentive regulation allows to control the congestion cost and, to a lesser extent, the investment costs of the network. This incentive regulation allows to compensate for the theoretical failures of redispatch related to the absence of internalization of externality. The regulation of system operation and of network ownership proposes to National Grid an arbitrage between the costs of system operation in the short and medium term and the investment costs of the network (Joskow, 2006). In this framework, the incentive regulation of system operation prompts National Grid to arbitrate between the congestion cost and transmission investments of small sizes (with short periods of return on investment). While the long run budget constraint incentivizes National Grid to arbitrate between the investments of small size and the investments of bigger size, the latter being able to be less expensive thanks to the economies of scale that characterize power grid.

3- c) Governance of the network and coordination between generation and transmission

Our analysis makes it possible to show that, to deal with congestion, light TSOs and heavy TSOs choose basically different methods. The light TSO like PJM focuses on the internalization of congestion in a price system, while the heavy TSO as National Grid concentrates on the development of the network.

The structure of governance of the network influences coordination between generation and transmission. Depending on its form, the governance incentivizes the TSO to focus either on internalization of congestion (with given transmission capacity) or on the development of the network (in order to treat the cause of these congestions). In practice, the

governance structure of the network makes it difficult to reconcile efficiently and simultaneously these two approaches of treatment of externalities.

Considering the performances of PJM and National Grid, we note that the module of network investment holds a central place in coordination between generation and transmission. Even if the system of PJM is best equipped in locational signals, the evolution of congestion cost on its zone shows that the investments in network were insufficient. Then coordination between the investments in generation and network was not satisfactory. Conversely, National Grid is more concerned with the long run coordination with generation. That can be easily understood since he owns the network and prefers to develop it to eliminate congestion.⁹

But considering the trend of congestion cost, the strategy of developing the network is more efficient. Of course, the locational signals are necessary to incentivize the location of power plants. But the generators have strong constraints of location to settle their new power stations. The primary energy source must be easily accessible. For the thermal power plants (with gas, coal or nuclear power), a river with an important flow is also necessary. Lastly, the generators must find lands that fit with these criteria at a reasonable price. These constraints for the generators lead to durable congestions for which the only solution is to develop the network.

The network investment then holds a central role in long-term coordination between generation and transmission, and this for two reasons. Firstly, the structure of governance of the network can result in setting up little or no coordination signals. As a consequence, the coordination signals do not guarantee that the cause of congestion, related to the lack of capacity of the network, is treated.

Conclusion

We have shown that the complementarities between the structure of governance of the network and the modules of management of power flows influence coordination between generation and transmission of electricity, and this in two manners. First of all, the structure of governance of the network defines the degree of unbundling of the TSO from the rest of the electric system, which modifies the incentives that he can perceive in the various options of power flow management of flows. Then, depending on the structure of governance, only the sub-optimal schemes might be applied, in particular when the optimal options are counterincentive for the TSO in the configuration of its governance. But the structure of governance can also correct some failures of these sub-optimal methods. The conclusions of our analysis are thus more moderate than those of other studies (Boucher and Smeers, 2002; Ehrenmann and Smeers, 2005). Because they show that it is still useful to study the effects of these options on coordination between generation and transmission. Then, the study of PJM and NGC in terms of complementarity showed that the module of investment of the network has more influence on coordination between generation and transmission than internalization of externalities.

Internalization of the externalities of use of the network is admittedly needed to effectively coordinate the production and the short-term and long-term transmission electricity. But, since the long term location of generators generates durable congestions on the network, only the development of transmission capacity brings a satisfactory coordination of these two activities. The module of investment of the network is thus the heart of coordination between generation and transmission of electricity. The complementarities show

⁹ This is also true when the locational signals are ineffective.

that the investment in network can be the only effective process of coordination between generation and transmission.

References

- Baldwin C., Clark K., 2000., Design Rules - The Power of Modularity. The MIT Press, Cambridge, Massachusetts and London, England
- Baker J. Jr., Tenebaum B., Woolf F., 1997. "Governance and regulation of power pools and system operators. An international comparison". Worldbank
- Boucher J., Smeers Y., 2002. "Towards a common European Electricity Market – Path in the right direction... still far from an effective design". *Journal of Network Industries* 3(4), 375-424
- Boyce J., Hallis A., 2005. "Governance of electricity transmission systems". *Energy Economics*, 27(2), 237-255
- Brunekreeft G., Neuhoff K., Newbery D., 2005. "Electricity transmission: an overview of the current debate". *Utilities Policy*, 13(2), 73-93
- Costello K., 2001. "Interregional coordination versus RTO mergers: a cost-benefit perspective". *The Electricity Journal*, 14(2) 13-24
- Ehrenmann A., Smeers Y., 2005. "*Inefficiencies in European congestion management proposals*". *Utilities Policy*, 13(2), 135-152
- Joskow P., 2006. "Patterns of transmission investment", in Lévêque F. (ed.), Competitive Electricity Markets and Sustainability. Edward Elgar, 131-186
- Joskow P., 2005. "Transmission Policy in the United States". *Utilities Policy*, 13(2), 95-115
- Lévêque F (Ed.), 2003. Transport Pricing of Electricity Network. Kluwer
- Perez Y., 2002. L'analyse néo-institutionnelle des réformes électriques européennes. Thèse de Doctorat en Sciences Économiques, Université de Paris I Panthéon – Sorbonne. In French
- Pérez-Arriaga I. J., Rubio F. J., Puerta J. F., Arceluz J., Marin J., 1995. "Marginal Pricing of Transmission Services: an analysis of cost recovery". *IEEE Trans. on Power Systems*, 10(1), 546-553
- PJM, 2004b. "PJM FERC Filing in Docket Number RT-01-2-01". Avril, www.pjm.com
- Rious .V, Glachant JM., Perez Y., Dessante P., 2008. "The diversity of design of TSOs". *Energy Policy* 36 (9), 3323– 3332
- Rossignoli J., Paravalos M. E., Besser J. G., 2005. "Transmission: The Critical Link Delivering the Promise of Industry Restructuring to Customers". *The Electricity Journal*, 18(9), 18-27
- Schweppe F., Caramanis M., Tabors R., Bohn R., 1988. Spot Pricing of Electricity. Kluwer Academic
- Wilson R., 2002. "Architecture of the power markets". *Econometrica*, 70(4), 1299-1344